

Department of Water and Sewer Utilities

A City We Can All Believe In

Andrea Hall Adebowale  
Director

Division of Water Supply  
612 Ridge Road  
Cedar Grove, NJ 07009  
973-239-4493

CITY OF NEWARK WATER DEPT  
PWS ID# 0714001  
LAB ID# 07014

Report of analysis:

Samples from the following locations were collected on 09/12/2016

**Location: 130 Norfolk Street, Basement Tap # 1**

ANALYSIS	RESULT	UNITS	METHOD	DATE ANALYZED
pH	7.55	pH units	EPA 150.1	09/12/16
Residual Chlorine	0.27	mg/L	SM 4500-Cl F	09/12/16
Turbidity	0.309	NTU	EPA 180.1	09/12/16
Color	3	CU	SM2120 B	09/12/16
Total Coliform per 100 ml	A	--	SM 9222 B	09/12/16
Heterotrophic plate count per ml	0	--	SM 9215 B	09/12/16

**Location: 130 Norfolk Street, Kitchen Sink #2, 4th Floor**

ANALYSIS	RESULT	UNITS	METHOD	DATE ANALYZED
pH	7.70	pH units	EPA 150.1	09/12/16
Residual Chlorine	0.55	mg/L	SM-4500Cl F	09/12/16
Turbidity	0.877	NTU	EPA 180.1	09/12/16
Color	7	CU	SM2120 B	09/12/16
Total Coliform per 100 ml	A	--	SM 9222 B	09/12/16
Heterotrophic plate count per ml	5	--	SM 9215 B	09/12/16

Selene Samuel  
City of Newark  
**Date: 09/15/2016**